



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA181933

Certificate Holder: Shenzhen Growatt New Energy Technology Co.,Ltd
1st East & 3rd Floor of Building A, Building B,
Jiayu Industrial Park, #28, GuangHui Road,
LongTeng Community, Shiyao Street, Baoan District,
Shenzhen,
P.R. China

Class Description: Non-Declared
Product Description: PV Grid Inverter

Brand Name: **Growatt**

Model No.: MAX 80KTL3 LV

Markings: Input: 1100Vdc Max, voltage range 200-1000Vdc

6x25A Isc PV 6x32A

Output: 3P+N+PE 230/400V~ 50Hz

3x128.8A 88800VA

Class I, IP65

Standard: IEC 62109-1 Ed. 1.0

IEC 62109-2 Ed. 1.0

AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: SAA181933 or RCM

Date First Registered: 17 July 2018

Date of Expiry: 17 July 2023

For and on Behalf of
SAA Approvals Pty Ltd




SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register

Issued: 23-07-18 181933/1b
Markings amended



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA181933

Date of Issue: 17 July 2018

Class Description: Non-Declared
Product Description: PV Grid Inverter

| Additional Models | Description |
|-------------------|--|
| MAX 50KTL3 LV | Input: 1100Vdc Max, MPPT voltage range 200-1000Vdc 6x25A Isc PV 6x32A Output: 3P+N+PE 230/400V~ 50Hz 3x80.5A 55500VA |
| MAX 60KTL3 LV | Input: 1100Vdc Max, MPPT voltage range 200-1000Vdc 6x25A Isc PV 6x32A Output: 3P+N+PE 230/400V~ 50Hz 3x96.6A 66600VA |
| MAX 70KTL3 LV | Input: 1100Vdc Max, MPPT voltage range 200-1000Vdc 6x25A Isc PV 6x32A Output: 3P+N+PE 230/400V~ 50Hz 3x112.7A 77700VA |
| MAX 60KTL3 MV | Input: 1100Vdc Max, MPPT voltage range 200-1000Vdc 6x25A Isc PV 6x32A Output: 3P+N+PE or 3P+PE 277/480V~ 50Hz 3x80.2A 66600VA |
| MAX 70KTL3 MV | Input: 1100Vdc Max, MPPT voltage range 200-1000Vdc 6x25A Isc PV 6x32A Output: 3P+N+PE or 3P+PE 277/480V~ 50Hz 3x93.6A 77700VA |
| MAX 80KTL3 MV | Input: 1100Vdc Max, MPPT voltage range 200-1000Vdc 6x25A Isc PV 6x32A Output: 3P+N+PE or 3P+PE 277/480V~ 50Hz 3x107A 88800VA |

For and on Behalf of
SAA Approvals Pty Ltd




SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register

Issued: 25-07-18 181933/2c
Model Descriptions amended